



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0K1729

Otsego Northern Catskills BOCES

Joshua Reiss
 31 Center Street
 Oneonta, NY 13820

Project Name: Otsego Area Occupational Center (OAOC)

Project / PO Number: 17-00947
 Received: 11/19/2020
 Reported: 12/28/2020

Analytical Testing Parameters

Client Sample ID:	157 Kitchen Prep Sink	Collected By:	JR-Client
Sample Matrix:	Drinking Water	Collection Date:	11/19/2020 5:48
Lab Sample ID:	J0K1729-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2119	DLO

Client Sample ID:	157 Kitchen Hand Wash Sink L	Collected By:	JR-Client
Sample Matrix:	Drinking Water	Collection Date:	11/19/2020 5:49
Lab Sample ID:	J0K1729-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2125	DLO

Client Sample ID:	157 Hand Wash Sink R	Collected By:	JR-Client
Sample Matrix:	Drinking Water	Collection Date:	11/19/2020 5:50
Lab Sample ID:	J0K1729-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2127	DLO

Client Sample ID:	157 Ice Machine	Collected By:	JR-Client
Sample Matrix:	Drinking Water	Collection Date:	11/19/2020 5:52
Lab Sample ID:	J0K1729-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2129	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1729

Client Sample ID: 157 Pot Filler	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:42
Lab Sample ID: J0K1729-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0299	0.015 AL	0.0010	mg/L		12/16/20 1430	12/18/20 1504	LLW

Client Sample ID: 153 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:54
Lab Sample ID: J0K1729-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2131	DLO

Client Sample ID: 153 Bottle Fill	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:53
Lab Sample ID: J0K1729-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2132	DLO

Client Sample ID: 150 Mens BR L	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:55
Lab Sample ID: J0K1729-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2138	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1729

Client Sample ID: 150 Mens BR R	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:55
Lab Sample ID: J0K1729-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2140	DLO

Client Sample ID: 148 Womens BR L	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:56
Lab Sample ID: J0K1729-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2142	DLO

Client Sample ID: 148 Womens BR R	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:56
Lab Sample ID: J0K1729-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2144	DLO

Client Sample ID: 129 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:58
Lab Sample ID: J0K1729-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2146	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1729

Client Sample ID: 146 Exam S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:59
Lab Sample ID: J0K1729-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.015 AL	0.0010	mg/L		12/16/20 1430	12/18/20 1506	LLW

Client Sample ID: 146 A S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:59
Lab Sample ID: J0K1729-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2150	DLO

Client Sample ID: 146 Br	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:59
Lab Sample ID: J0K1729-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2152	DLO

Client Sample ID: 139S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:01
Lab Sample ID: J0K1729-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2154	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1729

Client Sample ID: 141 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:02
Lab Sample ID: J0K1729-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2156	DLO

Client Sample ID: 143 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:02
Lab Sample ID: J0K1729-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2202	DLO

Client Sample ID: 136 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:03
Lab Sample ID: J0K1729-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2204	DLO

Client Sample ID: 134 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:04
Lab Sample ID: J0K1729-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2206	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1729

Client Sample ID: 132 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:05
Lab Sample ID: J0K1729-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2208	DLO

Client Sample ID: 132 S R	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:05
Lab Sample ID: J0K1729-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/16/20 1455	12/16/20 2210	DLO

Client Sample ID: 127 S L	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:07
Lab Sample ID: J0K1729-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.015 AL	0.0010	mg/L		12/16/20 1430	12/18/20 1507	LLW

Client Sample ID: 127 S C	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:07
Lab Sample ID: J0K1729-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.015 AL	0.0010	mg/L		12/16/20 1430	12/18/20 1509	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1729

Client Sample ID: 127 S R	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:07
Lab Sample ID: J0K1729-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1529	LLW

Client Sample ID: 102 Bottle Fill	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:09
Lab Sample ID: J0K1729-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1524	LLW

Client Sample ID: 110 BR	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:08
Lab Sample ID: J0K1729-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1531	LLW

Client Sample ID: 108 BR	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:09
Lab Sample ID: J0K1729-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1533	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1729

Client Sample ID: 112 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:11
Lab Sample ID: J0K1729-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1535	LLW

Client Sample ID: 116 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:12
Lab Sample ID: J0K1729-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1537	LLW

Client Sample ID: 118 BR	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:13
Lab Sample ID: J0K1729-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1542	LLW

Client Sample ID: 120 BR	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:13
Lab Sample ID: J0K1729-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1544	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1729

Client Sample ID: 156 BR	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:15
Lab Sample ID: J0K1729-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0041	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1546	LLW

Client Sample ID: 158A BR	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:17
Lab Sample ID: J0K1729-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1548	LLW

Client Sample ID: 165 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:23
Lab Sample ID: J0K1729-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1553	LLW

Client Sample ID: 167 BR	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:24
Lab Sample ID: J0K1729-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1550	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1729

Client Sample ID: 169 BR	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:24
Lab Sample ID: J0K1729-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1555	LLW

Client Sample ID: 175 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:26
Lab Sample ID: J0K1729-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1557	LLW

Client Sample ID: 168 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:31
Lab Sample ID: J0K1729-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1559	LLW

Client Sample ID: 172A S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:34
Lab Sample ID: J0K1729-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1604	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1729

Client Sample ID: 178 C S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:36
Lab Sample ID: J0K1729-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1606	LLW

Client Sample ID: 184 A	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 6:39
Lab Sample ID: J0K1729-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1608	LLW

Client Sample ID: 206 S	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:41
Lab Sample ID: J0K1729-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1610	LLW

Client Sample ID: 206A BR	Collected By: JR-Client
Sample Matrix: Drinking Water	Collection Date: 11/19/2020 5:42
Lab Sample ID: J0K1729-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/18/20 1030	12/18/20 1611	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1729

Definitions

- AL: US EPA Action Level
- MCL: US EPA Maximum Contaminant Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.***

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 12/28/2020 19:39

Chain of Custody

Customer: ONC BOCES
 Contact: Josh Reiss
 Project: OAOC Water Testing



10K1729
 Otsego Northern Catskills BOCES
 PM: Shannon Weeks

Sampled By: Josh Reiss
 Sampler Phone #: 607-286-7715 ext 2606

School County: Otsego
 School Type: K-12
 School Name: Otsego Area Occupational Center (OAOC)
 School ID:
 Sampling Event Name: Water Testing
 Building address: 1914 County Hwy 35 Millford NY 13807
 Building ID:

Lab ID	Sample Code	Sample Type	Fixture Code	Fixture Type	Fixture Type Use	Fixture Area Type	Fixture Location Description	Fixture Description	Building Floor #	Water Last Used		Sample Collected		Page
										Date	Time	Date	Time	
1		FIRST DRAW		Faucet, Cold	Consumption		157 Kitchen Prep Sink		1	11/18/2020	18:00	11/19/2020	5:48	X
2		FIRST DRAW		Faucet, Cold	Consumption		157 Kitchen Hand Wash Sink L		1	11/18/2020	18:00	11/19/2020	5:49	X
3		FIRST DRAW		Faucet, Cold	Consumption		157 Hand Wash Sink R		1	11/18/2020	18:00	11/19/2020	5:50	X
4		FIRST DRAW		Faucet, Cold	Consumption		157 Ice Machine		1	11/18/2020	18:00	11/19/2020	5:52	X
5		FIRST DRAW		Faucet, Cold	Consumption		157 Pot Filler		1	11/18/2020	18:00	11/19/2020	6:42	X
6		FIRST DRAW		Faucet, Cold	Consumption		153 S		1	11/18/2020	18:00	11/19/2020	5:54	X
7		FIRST DRAW		Faucet, Cold	Consumption		153 bottle fill		1	11/18/2020	18:00	11/19/2020	5:53	X
8		FIRST DRAW		Faucet, Cold	Consumption		150 Mens Br L		1	11/18/2020	18:00	11/19/2020	5:55	X
9		FIRST DRAW		Faucet, Cold	Consumption		150 Mens Br R		1	11/18/2020	18:00	11/19/2020	5:55	X
10		FIRST DRAW		Faucet, Cold	Consumption		148 Womens Br L		1	11/18/2020	18:00	11/19/2020	5:56	X
11		FIRST DRAW		Faucet, Cold	Consumption		148 Womens Br R		1	11/18/2020	18:00	11/19/2020	5:56	X
12		FIRST DRAW		Faucet, Cold	Consumption		129 S		1	11/18/2020	18:00	11/19/2020	5:58	X
13		FIRST DRAW		Faucet, Cold	Consumption		146 Exam S		1	11/18/2020	18:00	11/19/2020	5:59	X
14		FIRST DRAW		Faucet, Cold	Consumption		146 AS		1	11/18/2020	18:00	11/19/2020	5:59	X
15		FIRST DRAW		Faucet, Cold	Consumption		146 Br		1	11/18/2020	18:00	11/19/2020	5:59	X
16		FIRST DRAW		Faucet, Cold	Consumption		139S		1	11/18/2020	18:00	11/19/2020	6:01	X

17	FIRST DRAW	Faucet, Cold	Consumption		141 S		1	11/18/2020	18:00	11/19/2020	6:02	X
18	FIRST DRAW	Faucet, Cold	Consumption		143 S		1	11/18/2020	18:00	11/19/2020	6:02	X
19	FIRST DRAW	Faucet, Cold	Consumption		136 S		1	11/18/2020	18:00	11/19/2020	6:03	X
20	FIRST DRAW	Faucet, Cold	Consumption		134 S		1	11/18/2020	18:00	11/19/2020	6:04	X
21	FIRST DRAW	Faucet, Cold	Consumption		132 S		1	11/18/2020	18:00	11/19/2020	6:05	X
22	FIRST DRAW	Faucet, Cold	Consumption		132 SR		1	11/18/2020	18:00	11/19/2020	6:05	X
23	FIRST DRAW	Faucet, Cold	Consumption		127 S L		1	11/18/2020	18:00	11/19/2020	6:07	X
24	FIRST DRAW	Faucet, Cold	Consumption		127 S C		1	11/18/2020	18:00	11/19/2020	6:07	X
25	FIRST DRAW	Faucet, Cold	Consumption		127 SR		1	11/18/2020	18:00	11/19/2020	6:07	X
26	FIRST DRAW	Faucet, Cold	Consumption		102 Bottle Fill		1	11/18/2020	18:00	11/19/2020	6:09	X
27	FIRST DRAW	Faucet, Cold	Consumption		110 Br		1	11/18/2020	18:00	11/19/2020	6:08	X
28	FIRST DRAW	Faucet, Cold	Consumption		108 Br		1	11/18/2020	18:00	11/19/2020	6:09	X
29	FIRST DRAW	Faucet, Cold	Consumption		112 S		1	11/18/2020	18:00	11/19/2020	6:11	X
30	FIRST DRAW	Faucet, Cold	Consumption		116 S		1	11/18/2020	18:00	11/19/2020	6:12	X
31	FIRST DRAW	Faucet, Cold	Consumption		118 Br		1	11/18/2020	18:00	11/19/2020	6:13	X
32	FIRST DRAW	Faucet, Cold	Consumption		120 Br		1	11/18/2020	18:00	11/19/2020	6:13	X
33	FIRST DRAW	Faucet, Cold	Consumption		156 Br		1	11/18/2020	18:00	11/19/2020	6:15	X
34	FIRST DRAW	Faucet, Cold	Consumption		158A Br		1	11/18/2020	18:00	11/19/2020	6:17	X
35	FIRST DRAW	Faucet, Cold	Consumption		165 S		1	11/18/2020	18:00	11/19/2020	6:23	X
36	FIRST DRAW	Faucet, Cold	Consumption		167 Br		1	11/18/2020	18:00	11/19/2020	6:24	X
37	FIRST DRAW	Faucet, Cold	Consumption		169 Br		1	11/18/2020	18:00	11/19/2020	6:24	X

