



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

JOL0578

Otsego Northern Catskills BOCES

Project Name: Worcester Central School

Joshua Reiss
31 Center Street
Oneonta, NY 13820

Project / PO Number: 17-00916
Received: 12/03/2020
Reported: 12/31/2020

Analytical Testing Parameters

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date. Values include Kitchen RR FIRST DRAW Faucet, Cold, Drinking Water, JOL0578-01, Josh Reiss, 12/03/2020 5:18.

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: 0.0028, 0.015 AL, 0.0010, mg/L, 12/22/20 1817, 12/22/20 1957, LLW.

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date. Values include Kitchen Steam Kettle FIRST DRAW Faucet, Cold, Drinking Water, JOL0578-02, Josh Reiss, 12/03/2020 5:18.

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: <0.0010, 0.015 AL, 0.0010, mg/L, 12/22/20 1817, 12/22/20 2003, LLW.

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date. Values include Kitchen Tilt Kettle FIRST DRAW Faucet, Cold, Drinking Water, JOL0578-03, Josh Reiss, 12/03/2020 5:17.

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: <0.0010, 0.015 AL, 0.0010, mg/L, 12/22/20 1817, 12/22/20 2005, LLW.

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date. Values include Kitchen Prep Sink L FIRST DRAW Faucet, Cold, Drinking Water, JOL0578-04, Josh Reiss, 12/03/2020 5:19.

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: 0.0010, 0.015 AL, 0.0010, mg/L, 12/22/20 1817, 12/22/20 2006, LLW.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Kitchen Prep Sink R FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:19
Lab Sample ID: J0L0578-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2008	LLW

Client Sample ID: Kitchen Prep Sink Spray FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:19
Lab Sample ID: J0L0578-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2010	LLW

Client Sample ID: Room 133 L FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:21
Lab Sample ID: J0L0578-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2016	LLW

Client Sample ID: Room 133 Middle FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:22
Lab Sample ID: J0L0578-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2018	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Room 133 R FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:22
Lab Sample ID: J0L0578-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2020	LLW

Client Sample ID: Room 132 L FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:23
Lab Sample ID: J0L0578-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0118	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2022	LLW

Client Sample ID: Room 132 R FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:23
Lab Sample ID: J0L0578-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2023	LLW

Client Sample ID: Admin Kitchen Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:24
Lab Sample ID: J0L0578-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2027	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Admin BR FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:25
Lab Sample ID: J0L0578-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2029	LLW

Client Sample ID: Boys BR L (outside 110) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:27
Lab Sample ID: J0L0578-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2031	LLW

Client Sample ID: Boys BR Middle (outside 110) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:28
Lab Sample ID: J0L0578-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2033	LLW

Client Sample ID: Boys BR R (outside 110) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:28
Lab Sample ID: J0L0578-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2039	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Bottle Filler outside 110 FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:27
Lab Sample ID: J0L0578-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2041	LLW

Client Sample ID: Girls BR L (outside 110) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:27
Lab Sample ID: J0L0578-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2042	LLW

Client Sample ID: Girls BR Middle (outside 110) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:27
Lab Sample ID: J0L0578-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.015 AL	0.0010	mg/L		12/22/20 1817	12/22/20 2044	LLW

Client Sample ID: Girls BR R (outside 110) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:27
Lab Sample ID: J0L0578-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0069	0.015 AL	0.0010	mg/L		12/23/20 1317	12/28/20 1145	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Room 111 BR Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:30
Lab Sample ID: J0L0578-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2056	LLW

Client Sample ID: Room 111 Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:30
Lab Sample ID: J0L0578-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0094	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2102	LLW

Client Sample ID: Room 112 BR Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:32
Lab Sample ID: J0L0578-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2104	LLW

Client Sample ID: Room 112 Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:32
Lab Sample ID: J0L0578-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0091	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2105	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Room 113 BR Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:33
Lab Sample ID: J0L0578-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2107	LLW

Client Sample ID: Room 113 Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:33
Lab Sample ID: J0L0578-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0097	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2109	LLW

Client Sample ID: District Office BR Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:36
Lab Sample ID: J0L0578-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2115	LLW

Client Sample ID: District Office Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:38
Lab Sample ID: J0L0578-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0104	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2117	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Library Office Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:40
Lab Sample ID: J0L0578-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2119	LLW

Client Sample ID: Basement Hand Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:42
Lab Sample ID: J0L0578-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0363	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2121	LLW

Client Sample ID: Basement BR Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:42
Lab Sample ID: J0L0578-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2123	LLW

Client Sample ID: Bottle Fill West FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:48
Lab Sample ID: J0L0578-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2127	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Room 126 Ice Machine FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:43
Lab Sample ID: J0L0578-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2129	LLW

Client Sample ID: Room 126 Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:45
Lab Sample ID: J0L0578-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0066	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2130	LLW

Client Sample ID: Room 126 BR Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:45
Lab Sample ID: J0L0578-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2132	LLW

Client Sample ID: Room 127 Sink North FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:46
Lab Sample ID: J0L0578-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0202	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2138	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Room 127 Sink South FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:46
Lab Sample ID: J0L0578-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0089	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2140	LLW

Client Sample ID: Handicap BR Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:47
Lab Sample ID: J0L0578-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2142	LLW

Client Sample ID: Boys Coach BR FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:49
Lab Sample ID: J0L0578-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2144	LLW

Client Sample ID: Girls Coach BR FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:51
Lab Sample ID: J0L0578-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		12/22/20 1818	12/22/20 2146	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Ref's BR FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:52
Lab Sample ID: J0L0578-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0107	0.015 AL	0.0050	mg/L	D	12/23/20 1317	12/29/20 1146	LLW

Client Sample ID: Room 138 Sink R FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:53
Lab Sample ID: J0L0578-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2156	LLW

Client Sample ID: Room 138 Sink L FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:53
Lab Sample ID: J0L0578-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0064	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2202	LLW

Client Sample ID: Room 236 Mens BR Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:59
Lab Sample ID: J0L0578-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2203	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Room 236 Womens BR Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:59
Lab Sample ID: J0L0578-45	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2205	LLW

Client Sample ID: Room 236 Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 5:59
Lab Sample ID: J0L0578-46	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2207	LLW

Client Sample ID: Boys BR L (next to 213) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:03
Lab Sample ID: J0L0578-47	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2209	LLW

Client Sample ID: Boys BR Middle (next to 213) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:02
Lab Sample ID: J0L0578-48	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2215	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Boys BR R (next to 213) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:01
Lab Sample ID: J0L0578-49	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0036	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2217	LLW

Client Sample ID: Bottle Filler outside 211 FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:03
Lab Sample ID: J0L0578-50	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2219	LLW

Client Sample ID: Room 211 Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:04
Lab Sample ID: J0L0578-51	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2221	LLW

Client Sample ID: Room 206 Sink #66 FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:05
Lab Sample ID: J0L0578-52	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2223	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Room 205 Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:06
Lab Sample ID: J0L0578-53	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0104	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2227	LLW

Client Sample ID: Girls BR Sink R (outside 204) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:06
Lab Sample ID: J0L0578-54	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2229	LLW

Client Sample ID: Girls BR Sink Middle (outside 204) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:06
Lab Sample ID: J0L0578-55	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2231	LLW

Client Sample ID: Girls BR Sink L (outside 204) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:06
Lab Sample ID: J0L0578-56	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2233	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Room 204 Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:07
Lab Sample ID: J0L0578-57	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0134	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2239	LLW

Client Sample ID: Room 203 Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:08
Lab Sample ID: J0L0578-58	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2241	LLW

Client Sample ID: Room 202 Sink FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:09
Lab Sample ID: J0L0578-59	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2243	LLW

Client Sample ID: Girls BR R (outside 304) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:15
Lab Sample ID: J0L0578-60	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0050	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2245	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Girls BR Middle (outside 304) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:16
Lab Sample ID: J0L0578-61	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.015 AL	0.0010	mg/L		12/22/20 1819	12/22/20 2247	LLW

Client Sample ID: Girls BR L (outside 304) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:16
Lab Sample ID: J0L0578-62	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.015 AL	0.0010	mg/L		12/22/20 1820	12/22/20 2332	LLW

Client Sample ID: Bottle Filler outside 305 FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:15
Lab Sample ID: J0L0578-63	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		12/22/20 1820	12/22/20 2334	LLW

Client Sample ID: Boys BR R (outside 309) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:13
Lab Sample ID: J0L0578-64	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.015 AL	0.0010	mg/L		12/22/20 1820	12/22/20 2340	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L0578

Client Sample ID: Boys BR Middle (outside 309) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:13
Lab Sample ID: J0L0578-65	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.015 AL	0.0010	mg/L		12/22/20 1820	12/22/20 2342	LLW

Client Sample ID: Boys BR L (outside 309) FIRST DRAW Faucet, Cold	Collected By: Josh Reiss
Sample Matrix: Drinking Water	Collection Date: 12/03/2020 6:13
Lab Sample ID: J0L0578-66	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		12/22/20 1820	12/22/20 2344	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- D:** The sample was diluted due to matrix interference.
- MCL:** US EPA Maximum Contaminant Level
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 12/31/2020 14:04

Chain of Custody

Customer: ONC BOCES
 Contact: Josh Reiss
 Project: Worcester Central School



010578
 Otsego Northern Catskills BOCES
 PM: Shannon Weeks

Sampled By: Josh Reiss
 Sampler Phone #: 607-286-7715 ext 2606

School County: Otsego
 School Type: K-12
 School Name: Worcester Central School
 School ID: [Redacted]
 Sampling Event Name: Water Testing
 Building address: 198 Main Street, Worcester, NY 12197
 Building ID: [Redacted]

Lab ID	Sample Code	Sample Type	Fixture Code	Fixture Type	Fixture Type Use	Fixture Area Type	Fixture Location Description	Fixture Description	Building Floor #	Water Last Used		Sample Collected		pg
										Date	Time	Date	Time	
1		FIRST DRAW		Faucet, Cold	Consumption		Kitchen RR		1	12/2/2020	18:00	12/3/2020	5:15	X
2		FIRST DRAW		Faucet, Cold	Consumption		Kitchen Steam Kettle		1	12/2/2020	18:00	12/3/2020	5:18	X
3		FIRST DRAW		Faucet, Cold	Consumption		Kitchen Tilt Kettle		1	12/2/2020	18:00	12/3/2020	5:17	X
4		FIRST DRAW		Faucet, Cold	Consumption		Kitchen Prep Sink L		1	12/2/2020	18:00	12/3/2020	5:19	X
5		FIRST DRAW		Faucet, Cold	Consumption		Kitchen Prep Sink R		1	12/2/2020	18:00	12/3/2020	5:19	X
6		FIRST DRAW		Faucet, Cold	Consumption		Kitchen Prep Sink Spray		1	12/2/2020	18:00	12/3/2020	5:19	X
7		FIRST DRAW		Faucet, Cold	Consumption		Room 133 L		1	12/2/2020	18:00	12/3/2020	5:21	X
8		FIRST DRAW		Faucet, Cold	Consumption		Room 133 Middle		1	12/2/2020	18:00	12/3/2020	5:22	X
9		FIRST DRAW		Faucet, Cold	Consumption		Room 133 R		1	12/2/2020	18:00	12/3/2020	5:22	X
10		FIRST DRAW		Faucet, Cold	Consumption		Room 132 L		1	12/2/2020	18:00	12/3/2020	5:23	X
11		FIRST DRAW		Faucet, Cold	Consumption		Room 132 R		1	12/2/2020	18:00	12/3/2020	5:23	X
12		FIRST DRAW		Faucet, Cold	Consumption		Admin Kitchen Sink		1	12/2/2020	18:00	12/3/2020	5:24	X
13		FIRST DRAW		Faucet, Cold	Consumption		Admin BR		1	12/2/2020	18:00	12/3/2020	5:25	X
14		FIRST DRAW		Faucet, Cold	Consumption		Boys BR L (outside 110)		1	12/2/2020	18:00	12/3/2020	5:27	X
15		FIRST DRAW		Faucet, Cold	Consumption		Boys BR Middle (outside 110)		1	12/2/2020	18:00	12/3/2020	5:28	X

16	FIRST DRAW		Faucet, Cold	Consumption		Boys BR R (outside 110)		1	12/2/2020	18:00	12/3/2020	5:28	X
17	FIRST DRAW		Faucet, Cold	Consumption		Bottle Filler outside 110		1	12/2/2020	18:00	12/3/2020	5:27	X
18	FIRST DRAW		Faucet, Cold	Consumption		Girls BR L (outside 110)		1	12/2/2020	18:00	12/3/2020	5:27	X
19	FIRST DRAW		Faucet, Cold	Consumption		Girls BR Middle (outside 110)		1	12/2/2020	18:00	12/3/2020	5:27	X
20	FIRST DRAW		Faucet, Cold	Consumption		Girls BR R (outside 110)		1	12/2/2020	18:00	12/3/2020	5:27	X
21	FIRST DRAW		Faucet, Cold	Consumption		Room 111 BR Sink		1	12/2/2020	18:00	12/3/2020	5:30	X
22	FIRST DRAW		Faucet, Cold	Consumption		Room 111 Sink		1	12/2/2020	18:00	12/3/2020	5:30	X
23	FIRST DRAW		Faucet, Cold	Consumption		Room 112 BR Sink		1	12/2/2020	18:00	12/3/2020	5:32	X
24	FIRST DRAW		Faucet, Cold	Consumption		Room 112 Sink		1	12/2/2020	18:00	12/3/2020	5:32	X
25	FIRST DRAW		Faucet, Cold	Consumption		Room 113 BR Sink		1	12/2/2020	18:00	12/3/2020	5:33	X
26	FIRST DRAW		Faucet, Cold	Consumption		Room 113 Sink		1	12/2/2020	18:00	12/3/2020	5:33	X
27	FIRST DRAW		Faucet, Cold	Consumption		District Office BR Sink		1	12/2/2020	18:00	12/3/2020	5:36	X
28	FIRST DRAW		Faucet, Cold	Consumption		District Office Sink		1	12/2/2020	18:00	12/3/2020	5:38	X
29	FIRST DRAW		Faucet, Cold	Consumption		Library Office Sink		1	12/2/2020	18:00	12/3/2020	5:40	X
30	FIRST DRAW		Faucet, Cold	Consumption		Basement Hand Sink		1	12/2/2020	18:00	12/3/2020	5:42	X
31	FIRST DRAW		Faucet, Cold	Consumption		Basement BR Sink		1	12/2/2020	18:00	12/3/2020	5:42	X
32	FIRST DRAW		Faucet, Cold	Consumption		Bottle Fill West		1	12/2/2020	18:00	12/3/2020	5:48	X
33	FIRST DRAW		Faucet, Cold	Consumption		Room 126 Ice Machine		1	12/2/2020	18:00	12/3/2020	5:43	X
34	FIRST DRAW		Faucet, Cold	Consumption		Room 126 Sink		1	12/2/2020	18:00	12/3/2020	5:45	X
35	FIRST DRAW		Faucet, Cold	Consumption		Room 126 BR Sink		1	12/2/2020	18:00	12/3/2020	5:45	X

Chain of Custody

36	FIRST DRAW		Faucet, Cold	Consumption		Room 127 Sink North		1	12/2/2020	18:00	12/3/2020	5:46	X
37	FIRST DRAW		Faucet, Cold	Consumption		Room 127 Sink South		1	12/2/2020	18:00	12/3/2020	5:46	X
38	FIRST DRAW		Faucet, Cold	Consumption		Handicap BR Sink		1	12/2/2020	18:00	12/3/2020	5:47	X
39	FIRST DRAW		Faucet, Cold	Consumption		Boys Coach BR		1	12/2/2020	18:00	12/3/2020	5:49	X
40	FIRST DRAW		Faucet, Cold	Consumption		Girls Coach BR		1	12/2/2020	18:00	12/3/2020	5:51	X
41	FIRST DRAW		Faucet, Cold	Consumption		Ret's BR		1	12/2/2020	18:00	12/3/2020	5:52	X
42	FIRST DRAW		Faucet, Cold	Consumption		Room 138 Sink R		1	12/2/2020	18:00	12/3/2020	5:53	X
43	FIRST DRAW		Faucet, Cold	Consumption		Room 138 Sink L		1	12/2/2020	18:00	12/3/2020	5:53	X
44	FIRST DRAW		Faucet, Cold	Consumption		Room 236 Mens BR Sink		2	12/2/2020	18:00	12/3/2020	5:59	X
45	FIRST DRAW		Faucet, Cold	Consumption		Room 236 Womens BR Sink		2	12/2/2020	18:00	12/3/2020	5:59	X
46	FIRST DRAW		Faucet, Cold	Consumption		Room 236 Sink		2	12/2/2020	18:00	12/3/2020	5:59	X
47	FIRST DRAW		Faucet, Cold	Consumption		Boys BR L (next to 213)		2	12/2/2020	18:00	12/3/2020	6:03	X
48	FIRST DRAW		Faucet, Cold	Consumption		Boys BR Middle (next to 213)		2	12/2/2020	18:00	12/3/2020	6:02	X
49	FIRST DRAW		Faucet, Cold	Consumption		Boys BR R (next to 213)		2	12/2/2020	18:00	12/3/2020	6:01	X
50	FIRST DRAW		Faucet, Cold	Consumption		Bottle Filler outside 211		2	12/2/2020	18:00	12/3/2020	6:03	X
51	FIRST DRAW		Faucet, Cold	Consumption		Room 211 Sink		2	12/2/2020	18:00	12/3/2020	6:04	X
52	FIRST DRAW		Faucet, Cold	Consumption		Room 206 Sink #66		2	12/2/2020	18:00	12/3/2020	6:05	X
53	FIRST DRAW		Faucet, Cold	Consumption		Room 205 Sink		2	12/2/2020	18:00	12/3/2020	6:06	X
54	FIRST DRAW		Faucet, Cold	Consumption		Girls BR Sink R (outside 204)		2	12/2/2020	18:00	12/3/2020	6:06	X
55	FIRST DRAW		Faucet, Cold	Consumption		Girls BR Sink Middle (outside 204)		2	12/2/2020	18:00	12/3/2020	6:06	X

Chain of Custody

56	FIRST DRAW	Faucet, Cold	Consumption		Girls BR Sink L (outside 204)	2	12/2/2020	18:00	12/3/2020	6:06	
57	FIRST DRAW	Faucet, Cold	Consumption		Room 204 Sink	2	12/2/2020	18:00	12/3/2020	6:07	
58	FIRST DRAW	Faucet, Cold	Consumption		Room 203 Sink	2	12/2/2020	18:00	12/3/2020	6:08	X
59	FIRST DRAW	Faucet, Cold	Consumption		Room 202 Sink	2	12/2/2020	18:00	12/3/2020	6:09	X
60	FIRST DRAW	Faucet, Cold	Consumption		Girls BR R (outside 304)	3	12/2/2020	18:00	12/3/2020	6:15	X
61	FIRST DRAW	Faucet, Cold	Consumption		Girls BR Middle (outside 304)	3	12/2/2020	18:00	12/3/2020	6:16	X
62	FIRST DRAW	Faucet, Cold	Consumption		Girls BR L (outside 304)	3	12/2/2020	18:00	12/3/2020	6:16	X
63	FIRST DRAW	Faucet, Cold	Consumption		Bottle Filler outside 305	3	12/2/2020	18:00	12/3/2020	6:15	X
64	FIRST DRAW	Faucet, Cold	Consumption		Boys BR R (outside 309)	3	12/2/2020	18:00	12/3/2020	6:13	X
65	FIRST DRAW	Faucet, Cold	Consumption		Boys BR Middle (outside 309)	3	12/2/2020	18:00	12/3/2020	6:13	X
66	FIRST DRAW	Faucet, Cold	Consumption		Boys BR L (outside 309)	3	12/2/2020	18:00	12/3/2020	6:13	X
259											

Sampled By (signature)	Date/Time
Relinquished By (signature)	Date/Time
Relinquished By (signature)	Date/Time

Received By (signature)	Date/Time
Received By (signature)	Date/Time
Received By (signature)	Date/Time